



Wastewater Treatment Plant Review

City of Crosslake, Minnesota
November 14, 2016

11/11/2016

Outline of Review

- Review overall facility capacity by unit
- Review plant utilization
- Recommend improvements
- Discuss long range plans and funding




Existing Facility

- Constructed in 2004
- Wastewater Treatment Facility Capital Improvements Study prepared by WSN dated April 2016
- Permit up for renewal in 6 months
- No permit changes expected



Existing Facility

- 150,000 gallons per day (gpd) average flow permitted capacity (Average Wet Weather Flow – AWW)
- Peak Hourly Wet Weather (PHWW) flow estimated of 720,000 gpd or 500 gpm



Main Lift Station

- 12-inch gravity line feeds into
- Current capacity 500 gpm
- High flow can cause downstream overflows
- City is replacing lift pumps with smaller pumps
- Smaller pumps is temporary fix



Pretreatment

- Fine screen too large
- Grit separation adequate size
- Pipe to oxidation ditch (6-inch) undersized!
- Pipe size problem from start-up
- Requires increasing pipe size



Oxidation Ditch

- Meets both AWW and PHWW needs
- No current issues
- Effluent piping also adequate size



Secondary Clarifier

- Two clarifiers each 18' diameter
- Rated PHWW flow capacity 317 gpm
- Units undersized to handle PHWW flow!



Tertiary Filters


- Retro-fitted from original inefficient concept by staff
- Two filters 7.5-ft diameter each
- Rated capacity 264 gpm
- Significant size limitations!



Ultra-Violet (UV) Disinfection

- Meets both AWW and PHWW requirements





Current Flows

- Current AWW 55,000 gpd
- Peak one day flow 100,000 gpd
- Approximately 35% WWTP utilization on AWW basis
- Essentially 100% capacity on peak flow basis
- Requires flow equalization tank to buffer peak flows and maximize plant capacity

Flow Equalization / Backwash Holding Tank

- Primary WWTP issues are limited clarifier and filter capacity
- Constructing additional units difficult and costly
- Flow equalization and backwash holding can reduce peak flows and alleviate clarifier and filter size issues.



Flow Equalization / Backwash Holding Tank (cont.)

- Tank stores peak flows and pumps back during low flow periods
- Eliminates peak shock loads to clarifiers and filters
- Recommend installing between pretreatment and oxidation ditches
- Corrects piping bottleneck after pretreatment
- Allows plant to achieve permitted AWW capacity



Other Priority Items

- SCADA
- RAS/WAS valving and biosolids wasting
- Filter backwash holding tank and automation
- Ferric chloride flow pacing
- Generator sizing



Project Implementation

- Capacity issues should be addressed within the next 1-2 years
- Cost savings to do one large project versus phasing over 2-3 years
- Overall cost estimate \$900,000-\$1,200,000



Long Range Planning and Funding

- WWTP has significant remaining capacity
- Recommend growth plan on how to utilize capacity
- High median household income limits financing program
- Providing service to unsewered areas may make eligible for SRF low interest financing
- Recommend rate evaluation to determine project's impact on rates



Summary

- Approach is to fix hydraulic limitations of WWTP
- Other priority items
 - Flow Equalization/Backwash Holding Tank
 - SCADA Control System
 - Filter Backwash Supply Tank and Automation
 - RAS/WAS Valve Modifications
 - Ferric Chloride Flow Pacing
- City has great resource in WWTP capacity – need plan for utilization



Review of WSN Recommendations

- Control Building
 - Expand operations area
 - Already completed
 - SCADA System
 - Current facility has limited automation
 - SCADA systems critical to efficient operation



Pretreatment Building

- Air Blower
 - Piping undersized
 - Recommend new blower with enclosure
 - Recommend replacing air lift pump with self-priming pump
- Door Hardware and Hinges
 - Very corrosive environment
 - Most cost effective for staff to replace



Pretreatment Building (cont.)

- SCADA Controls
 - Recommend as part of overall SCADA
- Flowmeter replacement
 - Recommend replacement with connection to SCADA system



Pretreatment Building (cont.)

- Increase Height of Control Structure
 - Effluent pipe is too small
 - Wall height is poor fix
 - Significant issue as it restricts plant capacity
 - Recommend replacing pipe to fix root problem



Oxidation Ditches

- Brush Guard Replacement
 - Normal wear and tear
 - Most cost effective for staff to replace as needed
- Add Anoxic Zone for Denitrification and pH Control
 - May increase operator license requirements
 - pH control may be better handed with flow pacing ferric chloride
 - Voluntary addition may preclude grant eligibility



Final Clarifiers

- Building Insulation Cladding
 - Recommended to protect insulation
 - Already completed
- Skimmer Arm and Skirting Replacement
 - Skimmer arm broken and needs replacement



Final Clarifiers (cont.)

- Flow Pacing Ferric Chloride
 - Critical to maintain permit compliance
 - Overdosing impacts pH, corrodes metal and increases biosolids
 - Flow pacing standard particularly for variable flow facilities
 - Expect cost savings in reduced chemical usage



Wet Well (Plant Drain)

- Install Transducer and Modify Controls
 - Recommend flow equalization tank to fix root problem
 - Transducer not required with flow equalization tank



Sludge Pumps (RAS & WAS)

- Automatic Sludge Wasting
 - Original design is manual process
 - Minimum daily but preferably multiple times per day wasting
 - Significant staff time impact
 - Recommend automating with motorized valves and SCADA controls



Aeration Tank Modifications (Biosolids Storage Tank)

- Replace Aeration System
 - Original air piping design lacked risers above water level
 - Pipes filled with sludge and plugged
 - Need additional mixing around pump
- Sludge Pump Piping
 - Currently utilizing common pipe
 - Reduces operational flexibility
 - Recommend dedicated piping to each pump



Aeration Tank Modifications (cont.)

- Add Additional Biosolids Storage Tanks
 - Generally additional storage is good
 - Freezing concern with above grade tanks
 - Mixing required but would be difficult to install
 - Recommend more detailed cost analysis of contract disposal and reed beds
 - Determine if additional storage is required



Final Filter Modifications

- Original concept did not work
- City retrofitted to more traditional style
- Manual backwashes (multiple times per day) significant staff burden
- Filters are undersized and exasperate backwashing frequency
- Recommend converting to automatic backwash system with SCADA control
- Upsize plant drain lift pumps



Final Filter Modifications (cont.)

- Backwash water provided from holding tank
- Tank is too small to wash both filters
- Recommend adding additional tankage
- Tank should be dedicated to backwash
- Well water is option but effluent recycle works
- Siting a well at the plant site difficult with setbacks



Electrical Generator

- Does not run all critical components
- Additional motors may be required with future improvements
- Recommend replacing with larger unit with capacity for future loads

